

**ADDENDUM 002
REQUEST FOR BIDS
LIQUID STORAGE TANKS
RFB 1-080229FR**

Bidders should acknowledge receipt of Addendum 002 (TWO) by signing and including it with the original bid documents.

CHANGE TO SPECIFICATION MGS 93-02E, paragraph 2.1:

Current language:

2.1 The tank shall be a standard 1.9 specific gravity, seamless, vertical cylindrical, flat bottomed, dome topped with a minimum 24 inch vented manway and a 4 inch PVC U-type vent pipe installed.

Admended language:

2.1 The tank shall be a standard 1.9 specific gravity, seamless, vertical cylindrical, flat bottomed, dome topped with a minimum 24 inch vented man-way and a 4 inch PVC U-type vent pipe installed. **Tank shall meet ASTM 1998-06 or current revision.**

Accordingly, the change is believed to be of general interest to all potential bidders. All other specifications, terms and conditions remain unchanged and in full force.

THE BID CLOSING DATE REMAINS AS FEBRUARY 29, 2008, ON OR BEFORE 2:00 P.M., LOCAL TIME.

Vendor Business Name and Title of Signer (Print or type)	Name and Title of Department Authority Frankie J. Ryan Procurement Agent
Contractor/Offeror Signature <hr/> (Signature of person authorized to sign)	Missouri Department of Transportation Date Issued: February 27, 2008
Date Signed:	